## FIRE SAFETY CERTIFICATE

No.FBS2526C-57/01

Dated:11.06.2025

Certified that the Motilal Talera English Medium Primary & Secondary School, Moshi, Pune at Sector No 4, Plot No 2, Sant Nagar, Opp. Traffic Park, Village-Moshi, Taluka- Haveli, District- Pune- 412105 comprised of No basement(s) and four upper floors (G+4) owned by Camp Education Society and occupied by Motilal Talera English Medium Primary & Secondary School, Moshi, Pune have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 10.04.2025 (date of inspection) in the presence of Mr. Gaikwad Dilip Genu, Sub Fire Officer, Bhosari, Fire Department, Rajmata Jijau, Sub Fire Station, near PCMC garden, Landewadi Chowk and that the building/ premises is fit for occupancy upto classes X With effect from 11.06.2025 for a period of one year (10.06.2026) in accordance with rule and subject to specific conditions as appended:-

- 1. The Fire Hydrant System is tested and it is in working conditions.
- 2. The Fire Alarm & Smoke Detection Systems are in working conditions.
- 3. Fire Extinguishers are enough in number, and they are in working conditions.

4. Fire Extinguishers are on all floors and rooms.

Issued on 11.06.2025 at PCMC, Pune by

Signature with Seal

Name: Gaikwad Dilip Genu

Designation : Sub Fire Officer

Name & Address of Department/ Office:

Fire Department, Pimpri Chinchwad Municipal Corporation Pune - 18

To

Motilal Talera English/Medium Primary &

Secondary School Mosh, Pune

CES'S Motilal Talera Eng. Med. Primary & Secondary School, Moshi, Pune - 412 105. Principal
CES'S Motilal Talera Eng. Med.
Primary & Secondary School (CBSE)
Moshi, Pune - 412105